



NOTES:

1. NO WOOD SHALL BE USED FOR ADJUSTING CASTING.
2. CAST IRON FRAME AND COVER AS PER SPECIFICATIONS.
3. MANHOLE STEPS SHALL BE ALUMINUM, OR STEEL REINFORCED PLASTIC PER ASTM C478.
4. PRECAST REINFORCED CONCRETE MANHOLE SECTIONS PER ASTM C478 FURNISHED WITH O-RING GASKETS AND LUBRICANT EXCEPT AS OTHERWISE SPECIFIED. LIFT HOLES NOT PERMITTED IN MANHOLE SECTIONS.
5. INSTALL GATOR WRAP BY INFI-SHIELD AT ALL BARREL AND CONE SECTION EXTERNAL JOINTS.
6. PIPE CONNECTIONS TO MANHOLE SHALL BE MADE WATER TIGHT BY CAST IN PLACE RUBBER BOOT AND CEMENT MORTAR. INSIDE SURFACE SHALL BE FINISHED SMOOTH.

DESIGN:	DATE:		PLATE NUMBER
DRAWN:			S-1
REVISIONS	2/22/22 DRT	SANITARY MANHOLE	